

الآية

(وَقُلِ اعْمَلُوا فَسَيَرَى اللَّهُ عَمَلَكُمْ وَرَسُولُهُ وَالْمُؤْمِنُونَ وَسَتُرَدُّونَ إِلَى
عَالِمِ الْغَيْبِ وَالشَّهَادَةِ فَيُنَبِّئُكُمْ بِمَا كُنْتُمْ تَعْمَلُونَ)

صدق الله العظيم...

التوبة (104—105).

AKNOWLEDGMENT

First we need to thank fully our god (Allah) that without his blessing this work will not complete.

Then all thank for our supervisor Eng. Abdalgadir Basheer Banaga to his patience with us and countless hours and valuable efforts to guide and advise us to complete the work in his fair way.

Our thanks are for the staff of ELOBIED refinery to their main participation in success this work.

Thanks for Eng. Mosab M. Faddlallah for helping us to finish this research by giving all the data that we needed.

Thanks for Eng. Mohammed Osman for helping us to finish this research by giving all the data that we needed.

Lastly we need to thank our lecturers in petroleum refining and transportation department to their efforts in helping and support.

الاهداء

الي الذي يعطي دون مقابل ويكد من اجلنا
الي الذي بعث في روح الامل والعزيمة والبذل
الي الذي علمني معني الصبر والمثابرة والكفاح
الي الذي قادنا بعناية فائقة الي بر التعليم

الي منبع العطاء ابي ...

الي التي تسهر علي راحتنا وتضع تاج الوفاء
الي التي علمتني ان الحياة عطاء بلا حدود
الي التي ارضعتنا الالفة والمحبة والوفاء

الي منبع الحنان امي ...

الي الذين تجري دمائهم في اوردي وشرياني
الي الذين يرسمون البهجة علي وجهي
الي الذين أتذوق طعم الحياة بهم

اخواني واخواتي الاعزاء ...

الي الذين احس معهم بانني بين اخوتي
الي الذين امل ان يواصلو في درب النجاح
الي الذين لا اجد ما اعبر به عرفانا ووفاء لاياتهم

رفقاء دربي....

Abstract:

In this research data from Elobied refinery was used to calculate the energy losses for fixed roof tanks also this data was used to calculate losses for unisolated valves, flanges and pipes, In addition the efficiency for furnace and boiler was calculated. Energy losses for this equipment represented in dollars were 171666791\$, 5103685500\$, 5056491000\$, 1732662300\$ respectively, and the efficiency of heater and boilers were 66% & 87.4% respectively. Accordingly some remedies and treatments were proposed to decrease energy losses and increase energy efficiency.

Key words: energy efficiency, energy auditing, losses calculation.

التجريد

تم استخدام بيانات من مصفاة الأبييض لحساب الفاقد في الخزانات ذات السقوف الثابتة كما تم استخدام نفس البيانات لحساب فاقد الطاقة في كل من الأنابيب والصمامات والفنشات غير المعزولة كذلك تم حساب الكفاءة بالنسبة للأفران والغليات.

وجد ان فقدان الطاقة بالدولار في هذه المعدات 171666791\$, 5103685500\$, 5056491000\$, 1732662300\$ بالترتيب وكفاءة السخان والغلاية 66% و 87.4% بالترتيب. وفقا لذلك اقترحت بعض المعالجات لتقابل الطاقة المفقودة لزيادة الكفاءة .

List of Contents

Content	Page no
الآية	i
AKNOWLEDGMENT	ii
Dedication	iii
Abstract	iv
التجريد	v
List of Contents	vi
List of Figure	viii
List of Table	ix
Chapter One	
1.1 Introduction	1
1.2. Problem Statement	4
1.3. Objectives	4
Chapter Tow	
2.1. INTRODUCTION	5
2.2. Energy audit	6
2.3. History of Energy Audit	8
2.4 Benchmarking tools	10
2.5 Oil refining	11
2.6.1 Methods are used to control emissions from fixed roof Tanks	11
2.6.1.1 Emission Estimation Procedures	14
2.6.2 VALVES AND FLANGES: (numbering)	15
2.6.2.1 Types of valves	16
2.6.3 Boilers	21
2.6.4 Heaters (Furnaces)	22
2.7 Energy Conservation in Refineries of COSMO Oil (2006)	30
2.7.1 Process Modification	30
2.7.2. ORC Energy Audit Project Draft Final Report (2015)	31

2.7.3. G. A. R. rassoul and Tahseen hameed khlaif (2009)	32
Chapter Three	
3.1 Total Losses from Fixed Roof Tanks	33
3.2 Heat losses in uninsulated pipes	43
3.3 Estimated BTU losses for valve and flanges	43
3.4. Boilers	44
3.5. heat losses in furnace	44
3.6. Design of heat exchanger	45
Chapter Four	
4.1. Calculate the Energy losses in storage tank	47
4.2. Calculate the Energy losses in pipe	49
4.3. Calculate the Energy losses in valves	50
4.4. Calculate the Energy losses in flanges	53
4.5. Calculate the efficiency of heaters	55
4.6. Calculate the efficiency of boilers	55
Chapter Five	
5.1 Conclusion	58
5.2 Recommendation	58

List of Figure

Figure	Page No
Fig 2.1 Elobied refinery	6
Fig:2.2. floating roof tank	13
Fig:2.3. floating roof tank	14
Fig.2.4. Gate Valve	16
Fig 2.5.globe valve	17
Fig 2.6. angle valve	17
Fig..2.7. check valve	18
Fig.2.8. horizontal/vertical check valves	19
Fig.2.9. safety valve	20
Fig.2.10. ball valve	21
Fig . 2.11. boiler	22
Fig .2.12. flame shape	24
Fig .2.13. Oxygen Starvation	25
Fig .2 .14. construction of furnace and operation	26
Fig. 2.15.Horizontal BOX furnaces with radiant cell	27
Fig .2.16.Vertical furnace with radiant cell	27
Fig.2.17. Draft reading	28
Fig .2.18. Typical fired heater flow scheme air preheater	29
Fig.2.19. Trend of Energy Conservation in Cosmo	31
Fig.3.1 boiler operation	44

List of Table

Table	Page No
Table: 2.1. products of refinery	5
Table:2.2 units	5
Table:2.3 COSMO Oil	30
Table:2.4.Potential saving in preheat train	32
Table: 2.5 Summary of potential savings in insulation	32
Table: 4.1 data of storage tank	47
Table: 4.2 storage tank	48
Table: 4.3 storage tank	48
Table: 4.4 storage tank	48
Table: 4.5. Energy losses in pipe	49
Table: 4.6. Energy losses in pipe	49
Table: 4.7. Heat exchangers area	50
Table: 4.8. Boiler area	50
Table: 4.9. CDU area	51
Table: 4.10. heaters area	52
Table: 4.11. Total losses in all valves	52
Table: 4.12. . heat exchangers area	53
Table: 4.13. Boiler area	53
Table: 4.14. CDU area	54
Table: 4.15. heaters area	54
Table: 4.16. Total losses in all flanges	54
Table: 4.17. The efficiency of heaters	55
Table: 4.18. . efficiency of boilers	55
Table: 4.19. . The total losses are	56
Table: 4.20. . data of design heat exchanger	56
<i>Table: 4.21. data of design heat exchanger</i>	56
Table: 4.22. solution	57