

APPENDIXES

APPENDIX A: Tables of electrical safety level in terms of checklist's sections

.Table A-1: illustrates the sections and items of checklist

Items of checklist's sections	Checklist's sections
Protection of flexible cords from damage, and they aren't located in damp or wet .locations and keep out of the way of traffic	-1
2- Extension cords and Adapters that eliminate the equipment ground (3-prong to 2-prong adapters) are prohibited.	-3
Using the right gauge and type of wire size (AWG) to carry the current being drawn and comply with associated standards and .practices	-3
4- Extension cords in use of the three-wire type and used with the grounded plugs with a minimum wire size of (14 AWG = 5.9 A). An alternate source of power (more than one source of power), and it has capacity to .meet 100% of demand	-1
2- Using an emergency power system in hospital. (Restore power within 10 s after interruption of the normal power.)	
3- Using Un-Interrupted Power System in hospital.	
4- Installation of Power Cables and electrical wires according to Color Code.	
5- Medical Isolated power systems (IPS) are used especially in operating room and when a location is classified as a wet location.	
6- Grounded power systems are used.	
7- Receptacles are of the grounding type. and electrically connected to the equipment grounding conductor.	
8- Receptacles installed in damp locations are protected by GFCI.	
9- All Plugs, outlets, switches and are in good condition and working properly. and All live parts are covered.	
10-An adequate number of outlets/circuits provided to avoid overloading of circuits.	
11-Any device have receptacle (number of receptacle are appropriate).	

**Section I:
electrical cords
and extension
cords**

**:Section II
Power system
and power
Distribution**

12-Panel box (used to supply Voltage service to the receptacles, The isolation transformer and circuit breaker) for operating room , CCU and ICU?

13-Cables operating on high volts are shielded to confine voltage stresses to the insulation.

All electrical equipment is grounded -1
.effectively

The patient environment and metal fixed -2
.electrical equipment are grounded

All electrical components are bonded -3
together in grounding system (equipotential .(bonding

All protectively earthed equipment must use -4
.a 3-pin plug

The grounding electrode conductor size -5
adequate. (At least #2 in AWG =94 .(ampere

.The residual current devices (RCD) are used -1

The line isolation monitors (LIMs) are used -2
.with IPS

Proper personal protective equipment (PPE) -3
.is always used

.Defibrillation tester (analyzer) is used -4

5- Electro surgical tester is used.

.Electrical safety analyzer is used -6

Ground fault circuit interrupters (GFCI) are -7
.used, and they tested periodically

.All outlets protected by a GFCI -8

Appropriate fire extinguishers available and -9
.in good condition

Continuity of grounding wire is tested -10
.periodically

Bedrails and bed frame are made of plastic -11
or covered in insulating material

1- Visually inspect for electrical equipment
before use.

2- Instrumentations in all intensive care areas,
operating room, and special procedures
room are inspected at bimonthly intervals,
other equipments shall be tested quarterly.

3- Employees are aware of the hazards
associated with power electronic Equipment,
and taken Basic Electrical Safety for
Maintenance Employees. And trained to
think and react to electrical safety hazards.

4- Technicians are available all the time to
emergency situation's related to patient
safety.

:Section III Grounding system

Section IV: Testing and Protective devices

Section IIV: Evaluation of electrical safety program

- 5- All monitoring and patient care equipment in special care area's are checked for proper performance and calibration periodically.
- 6- The hospital has inspection, testing and evidence of maintenance program, in place to ensure that electrical apparatus is safe to use.
- 7- Protectively earthed equipment is tested every 6 months and double insulated equipment every 12 months.
- 8- All electrical equipment must be inspected for electrical safety before initial use, after repair, or when a problem is suspected.
- 9- Electrical equipment inspected and maintained according to manufacturer's instructions.

Scale										Items o of Section en I
High	113	727	3.85	819	140	00	Frequency			1
				19.5	46.3	34.1	00	Percent (%)		
Middle	156	997	3.39	512	1536	137	71	Frequency		2
				12.2	36.6	31.7	17.1	Percent (%)	2.4	
High	140	897	3.54	512	189	123	66	Frequency		3
				12.2	43.9	29.3	14.6	Percent (%)	0	
Middle	139	891	3.39	512	123	189	66	Frequency		4
				12.2	29.3	34.9	14.6	Percent (%)	0	
High	108	695	3.54	2314	6439	5732	1911	Frequency	1	Result of Section n I
						5	6	Percent (%)	2.4	

Table A-2: Distribution of the answer and results of electrical safety level in terms of electrical cords and extension cords

Table A-3: Distribution of the answer and results of electrical safety level in terms of power system and power distribution

									Scale	Members of Section II
Highest	122	0.78	4.2	1741.5	1536.3	922	00	00	Frequency Percent (%)	1
High	192	1.22	3.46	1024.4	1024.4	1434.1	37.3	49.8	Frequency Percent (%)	2
High	192	1.21	3.62	1229.3	1126.8	922	614.6	24.9	Frequency Percent (%)	3
High	171	1.09	3.46	922	1126.8	1126.8	1024.4	00	Frequency Percent (%)	4
None	140	0.89	1.51	12.4	00	512.2	717.1	2868.3	Frequency Percent (%)	5
High	172	1.09	3.49	922.0	1229.3	1024.4	1024.4	00	Frequency Percent (%)	6
High	164	1.04	3.59	922.0	1331.7	1331.7	512.2	12.4	Frequency Percent (%)	7

Low	150	0.96	1.85	00	24.90	104	920	208	Frequency Percent (%)	8
High	160	1.02	3.83	1434	1024	137	49.80	0	Frequency Percent (%)	9
High	167	1.06	3.76	1229	1431	85	717	0	Frequency Percent (%)	10
High	150	0.96	3.98	1536	1331	107	324	0	Frequency Percent (%)	11
None	143	0.90	1.58	12.40	0	512	922	250	Frequency Percent (%)	12
Middle	128	0.82	4.32	2048	1639	30	24.90	0	Frequency Percent (%)	13
Middle	089	574	3.28	1299	1277	1203	755	801	Frequency Percent (%)	Result of Section II

Table A-4: Distribution of the answer and results of electrical safety level in terms of grounding system

									Scale	Items of Section III
High	0.15	0.99	3.41	717	1126	156	85	0	Frequency Percent (%)	1
Middle	0.16	1.03	3.07	2	15	10	12	2	Frequency	2

				4.9	36.6	24.4	29.3	4.9	Percent (%)	
Middle	0.15	0.98	3.07	2	14	11	13	1	Frequency	3
				4.9	34.1	26.8	31.7	2.4	Percent (%)	
Middle	0.14	0.92	3.2	5	6	23	6	1	Frequency	4
				12.2	14.6	56.1	14.6	2.4	Percent (%)	
Middle	0.17	1.06	3.33	5	13	13	6	2	Frequency	5
				12.2	31.7	31.7	14.6	4.9	Percent (%)	
Middle	.128	.820	3.22	21	59	72	45	6	Frequency	Result of section III
				4.2	11.8	14.4	9	1.2	Percent (%)	

Table A-5: Distribution of the answer and results of electrical safety level in terms of testing and protective devices

									Scale	Items o of Section e IV
None	0.059	0.381	1.17	0	0	0	7	34	Frequency	1
				0	0	0	17.1	82.9	Percent (%)	
None	0.087	0.558	1.2	0	1	0	5	35	Frequency	2
				0	2.4	0	12.2	85.4	Percent (%)	
Low	0.143	0.915	2.37	0	4	15	14	8	Frequency	3
				0	9.8	36.6	34.1	19.5	Percent (%)	

None	185.	0.94 1	1.6 2	0 0	2 4.9	2 4.9	6 14. 6	16 39. 0	Frequency Percent (%)	4
None	167.	0.85 2	1.3 8	0 0	1 2.4	3 7.3	1 2.4	21 51. 2	Frequency Percent (%)	5
None	086.	0.54 9	1.2 7	0 0	0 0	2 4.9	7 17. 1	32 78. 0	Frequency Percent (%)	6
None	041.	0.26 4	1.0 7	0 0	0 0	0 0	3 7.3	38 92. 7	Frequency Percent (%)	7
None	166.	0.74 6	1.5 1	0 0	1 2.4	3 7.3	12 29. 3	25 61. 0	Frequency Percent (%)	8
High	168.	1.07 4	3.4 4	6 14. 6	16 39. 0	11 26. 8	6 14. 6	2 4.9	Frequency Percent (%)	9
Low	156.	0.99 9	2.0 5	0 0	3 7.3	12 29. 3	10 24. 4	16 39. 0	Frequency Percent (%)	10
High	127.	0.81 2	3.8 8	9 22. 0	20 48. 8	10 24. 4	2 4.9	0 0	Frequency Percent (%)	11
Low	095 7	0.61 2	1.9 3	15 1.3 6	48 4.3 6	58 5.2 7	73 6.6 4	22 20. 6	Frequency Percent (%)	Result of Section IV

Table A-6: Distribution of the answer and results of electrical safety level in terms evaluation of electrical safety program

									Scale	Items o of Section e IIV W
High	0.16 3	1.04 4	3.9	15 36. 6	12 29. 3	9 22. 0	5 12. 2	0 0	Frequency Percent (%)	1
Middle	0.17	1.07	3.3	5	15	10	6	2	Frequency	2


	5	9	9	12. 2	36. 6	24. 4	14. 6	4.9	Percent (%)		
Middle	0.19 6	1.25 5	3.2 2	7 17. 1	11 26. 8	12 29. 3	6 14. 6	5 12. 2	Frequency Percent (%)		3
High	0.16 2	1.03 7	3.9 8	15 36. 6	15 36. 6	7 17. 1	3 7.3	1 2.4	Frequency Percent (%)		4
High	0.15 6	0.98 4	3.5 8	7 17. 1	16 39. 0	10 24. 4	7 17. 1	0 0	Frequency Percent (%)		5
Middle	0.15 4	0.97 1	3.0 8	3 7.3	11 26. 8	12 29. 3	14 34. 1	0 0	Frequency Percent (%)		6
Low	0.15 6	0.99 9	1.9 5	1 2.4	1 2.4	10 24. 4	12 29. 3	17 41. 5	Frequency Percent (%)		7
High	0.13 5	0.86 7	3.4 4	4 9.8	16 39. 0	15 36. 6	6 14. 6	0 0	Frequency Percent (%)		8
High	0.13 6	0.86 9	3.5 4	6 14. 6	14 34. 1	17 41. 5	4 9.8	0 0	Frequency Percent (%)		9
Middle	0.095 7	0.61 28	3.3 3	63 7.0	11 12. 3	10 11. 3	63 7.0	25 2.7 8	Frequency Percent (%)	Result of Section IIV	

APPENDIX B: Table showing probabilities (areas) under the [probability density function](#) of the [t distribution](#) for different [degrees of freedom](#) (df)

0.25	0.1	0.05	0.025	0.01	0.005	0.0025	0.001	one-tail <i>p</i>
0.5	0.2	0.1	0.05	0.02	0.01	0.005	0.002	two-tail <i>p</i>
1.000	3.078	6.314	12.71	31.82	63.66	127.3	318.3	df = 1
0.816	1.886	2.920	4.303	6.965	9.925	14.09	22.33	2

0.765	1.638	2.353	3.182	4.541	5.841	7.453	10.21	3
0.741	1.533	2.132	2.776	3.747	4.604	5.598	7.173	4
0.703	1.383	1.833	2.262	2.821	3.250	3.690	4.297	9
0.681	1.306	1.688	2.028	2.434	2.719	2.990	3.333	36
0.681	1.305	1.687	2.026	2.431	2.715	2.985	3.326	37
0.681	1.304	1.686	2.024	2.429	2.712	2.980	3.319	38
0.681	1.304	1.685	2.023	2.426	2.708	2.976	3.313	39
0.681	1.303	1.684	2.021	2.423	2.704	2.971	3.307	40
0.681	1.303	1.683	2.020	2.421	2.701	2.967	3.301	41
0.680	1.302	1.682	2.018	2.418	2.698	2.963	3.296	42

.Table of Upper-Tail and Two-Tail t Critical Values



APPENDIX C: Table of critical values for the F distribution (for
:(use with ANOVA

.Critical values of F for the 0.05 significance level

	1	2	3	4	5	6	7	8	9	10
1	161.45	199.50	215.71	224.58	230.16	233.99	236.77	238.88	240.54	241.88
2	18.51	19.00	19.16	19.25	19.30	19.33	19.35	19.37	19.39	19.40
3	10.13	9.55	9.28	9.12	9.01	8.94	8.89	8.85	8.81	8.79
4	7.71	6.94	6.59	6.39	6.26	6.16	6.09	6.04	6.00	5.96
5	6.61	5.79	5.41	5.19	5.05	4.95	4.88	4.82	4.77	4.74
6	5.99	5.14	4.76	4.53	4.39	4.28	4.21	4.15	4.10	4.06
7	5.59	4.74	4.35	4.12	3.97	3.87	3.79	3.73	3.68	3.64
8	5.32	4.46	4.07	3.84	3.69	3.58	3.50	3.44	3.39	3.35
9	5.12	4.26	3.86	3.63	3.48	3.37	3.29	3.23	3.18	3.14
10	4.97	4.10	3.71	3.48	3.33	3.22	3.14	3.07	3.02	2.98
11	4.84	3.98	3.59	3.36	3.20	3.10	3.01	2.95	2.90	2.85
12	4.75	3.89	3.49	3.26	3.11	3.00	2.91	2.85	2.80	2.75
13	4.67	3.81	3.41	3.18	3.03	2.92	2.83	2.77	2.71	2.67
14	4.60	3.74	3.34	3.11	2.96	2.85	2.76	2.70	2.65	2.60
15	4.54	3.68	3.29	3.06	2.90	2.79	2.71	2.64	2.59	2.54
16	4.49	3.63	3.24	3.01	2.85	2.74	2.66	2.59	2.54	2.49
17	4.45	3.59	3.20	2.97	2.81	2.70	2.61	2.55	2.49	2.45
18	4.41	3.56	3.16	2.93	2.77	2.66	2.58	2.51	2.46	2.41
19	4.38	3.52	3.13	2.90	2.74	2.63	2.54	2.48	2.42	2.38
20	4.35	3.49	3.10	2.87	2.71	2.60	2.51	2.45	2.39	2.35
36	4.11	3.26	2.87	2.63	2.48	2.36	2.28	2.21	2.15	2.11
37	4.11	3.25	2.86	2.63	2.47	2.36	2.27	2.20	2.15	2.10
38	4.10	3.25	2.85	2.62	2.46	2.35	2.26	2.19	2.14	2.09
39	4.09	3.24	2.85	2.61	2.46	2.34	2.26	2.19	2.13	2.08
40	4.09	3.23	2.84	2.61	2.45	2.34	2.25	2.18	2.12	2.08